Office of the Junior Chemist
Public Health Engineering Department, Rajasthan
District Laboratory, Ganganagar

Report of the Bacteriological Examination of Water

Lt No. 552
25/06/2026

Date : 25/06/2026

To,
Principal,
Calgary Public School ,
5-NP Buddha Johad.

District : GANGANAGAR

Sample Taker : Your Self

Reference No : 68, Dated : 22/06/2026
Date of Receipt : 22/06/2026
Date of Exam : 22/06/2026

Sample No.	Date & Time of Collection	Village / Town / City	Source Name	Location	Residual Chlorine (in mg/L)	Total Coli Form Organism (MPN per 100 ml)	Remark (As per T-Coli Form)	Remark (Water)
813	22/06/2026	Raisinghnagar (M)	R.O. Unit	Calgary Public School Water Point No-1	-	Nil	Satisfactory	Potable

Note : (1) Samples are not collected by laboratory.
(2) Report is not valid for water quality legal purposes.

No.Lab./Tech.(Bact)/2026-27/813

Junior Chemist
PHED Laboratory, Ganganagar
कनिष्ठ रसायनज्ञ
जन स्वा. अभि. विभाग
जिला-प्रयोगशाला, श्रीगंगानगर
ई.डी.ओ.कोड नं. : 10484

Gurpreet Singh
Principal
Calgary Public School
Buddha Johad

PRESIDENT
Shahid Bhai Sukha Singh Mehtab Singh
Charitable Foundation, Budha Johar

Office of the Junior Chemist
Public Health Engineering Department, Rajasthan
District Laboratory, Ganganagar

Report of the Chemical Examination of Water

557
25/6/2026

To
Principal ,
calgary public School ,
Budhha johad.

Reference No : 68, Dated : 22/06/2026

Date of Receipt : 22/06/2026

District : GANGANAGAR
Block : RAISINGHNAGAR
Sample Taker : Sh Ramsawroop

Source	Permissible Value as per B.I.S : 10500/2012		R.O. Unit
Location			Galgary public School 5 NP
Other Habitation	Desirable Limit	Permissible limit in absence of alternate Source	5 NP
Village/Town			5 NP
Gram Panchayat			DABLA
Date of Collection			22/06/2026
Date of Examination			23/06/2026
Sample No.			280

Note:- All results except pH are in mg/L

pH	6.5 to 8.5	No relaxation	7.9
Turbidity(NTU)	1	5	1
Colour	5	15	Colourless
Odour	Agreeable	Agreeable	Smell less
Temperature	---	---	---
Total Alkalinity	200	600	90
Total Hardness (as CaCO3)	200	600	110
Calcium (as Ca)	75	200	16
Magnesium (as Mg)	30	100	17.08
Chloride(as Cl)	250	1000	20
Sulphate(as SO4)	200	400	---
Nitrate as(NO3)	45	45	2
Fluoride	1.0	1.5	0.23
Total Dissolved Solids	500	2000	220
Iron	1.0	No Relaxation	---
Residual Chlorine	0.2	1.0	0

Note : (1) Samples are not collected by laboratory.
(2) Report is not valid for water quality legal purposes.

(प्रभा कंसल)
कनिष्ठ रसायनज्ञ
जन स्वा. अभि. विभाग
जिला-प्रयोगशाला, श्रीगंगानगर
Junior Chemist
PHED Laboratory, Ganganagar

Remarks : Water is Potable (P)/Unpotable (U)
No.Lab./Tech.(chem)/2026-27/280

Page : 1

Gurpreet Singh
Principal
Calgary Public School
Buddha Johad

PRESIDENT
Shahid Bhai Sukha Singh Mehtab Singh
Charitable Foundation, Budha Johar

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 506 Dated: 29-06-2026

It is certified that an inspection team headed by

INDRAJ SINGH DAGLA (AEN) (Name of Officers with designation)

from SUB DN. RAISINGHNAGAR PHED

inspected the CALGARY PUBLIC SCHOOL, V-5NP DABLA, T-RAISINGHNAGAR (Name & Address of the school) on 29/06/2026 (date of inspection) and on the basis

of Water Test Report (Attached) bearing no. 552 to 557

dated 25/06/2026 of DISTRICT LAB, GANGANAGAR (PHED Lab)

certified that the

CALGARY PUB. SCHOOL, V-5NP, DABLA (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 29/06/2027

(इन्द्राज सिंह डागला)

Signature with Seal: सहायक अभियन्ता

Name : जन स्वा. अभि. विभाग

Designation : उपखण्ड रायसिंहनगर

Name & Address of the Office / Department 17452

To CALGARY PUBLIC SCHOOL & VILLAGE-5NP DABLA TEH-RAISINGHNAGAR, DISTT.-SRIGANGANAGAR (RAJ.) (PIN CODE - 335039)
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Gurjit Singh
Principal
Calgary Public School
Buddha Johad

PRESIDENT
Shahid Bhai Sukha Singh Mehtab Singh
Charitable Foundation, Budha Johar